Format No: CP/TF/01

TEST REPORT OF CEMENT CONCRETE CUBES

Lab ID : **CP-2019-08-16-51** **Date: 18/07/2019**

Customer : Assistant Executive Engineer, Yelahanka Sub Division, BBMP, Bangalore.

Address : Yelahanka Sub Division, BBMP, Bangalore.

Project Name : Improvements to Roads and Drain at Kondappa Layout 17th Cross and 20th Cross Road in Chowdeshwari Ward No-02.

Agency : Sri.N Lokanath Reddy, No.05, Kaveri Nagar, 7th Cross, Kavalu Byrasandra, R T Nagara(Post), Bangalore-32.

Customer's Reference : EE(YNK D)E-PMT-09/W.O/20/2019-20

Source of Sample : Sample supplied by Agency

Sample Condition : Satisfactory

Date of Receipt : 13-07-19

Customer ID : Cement Concrete Pavement

Sample Type /Size : 150X150X150 mm

Sample grade/Age : M30 / 7 Days Compressive Strength

Reference to BIS codes : IS: 516 - 1959 Methods of Tests for Strength of Concrete Cl.5

Date of test : 18/07/2019

Sl. No.	Identification Mark	Grade of concrete	Date of Casting	Date of Testing	Dimension of the Specimen (mm)	Cross sectional area (Sq.mm)	Weight of the sample (kg)	Failure Load (KN)	Compressive strength (N/mm^2)	Average Compressive Strength (N/mm^2)
1	Cement Concrete Pavement	M30	11/07/2019	18/07/2019	149.61 X 151.28 X 151.76	22632	**8.120**	574.5	25.4	25.4
2	Cement Concrete Pavement	M30	11/07/2019	18/07/2019	149.93 X 150.35 X 151.68	22541	**8.223**	595.7	26.4	
3	Cement Concrete Pavement	M30	11/07/2019	18/07/2019	150.30 X 150.47 X 150.89	22615	**8.536**	549.0	24.3	

Note:
The results pertain to the samples received and tested.
All information furnished by Customer/Representative
Any correction in the report will make this report invalid
This report without prior written approval should not be reproduced or published in full or part.
Samples will be disposed after 90 days from the date of issue of test certificate

A.E.E AE-02

FOR CIVIL Pro.

CIVIL Pro Sig..... Date..... BANGALORE

R KARTHIK RECHAN
Authorized Signatory
Quality Manager

Page 1/1
****End of Report****

Scanned by CamScanner